



INSPECTION CARD

BOOSTER UNIT

COD.

Production order N°: D01234330 2

60122663

Type

2KVC A.D. 35/120 M 230/50-60

SERIAL N°: 27312

VISUAL CHECK

INSPECTION OF HYDRAULIC - ELECTRIC COMPONENTS:

QUANTITY - TYPE- MANUFACTURER- INTEGRITY

X

MECHANICAL CONNECTIONS - ELECTRICAL CONNECTIONS - LABELING

SETTING

PRESSURE SWITCHES - PR1 [bar].....	
PRESSURE SWITCHES - PR2 [bar].....	
PRESSURE SWITCHES - PR3 [bar].....	
PRESSURE SWITCHES - PR4 [bar].....	
JOCKEY PUMP CONTROL PRESSURE SWITCH.....	
NO LOAD PRESSURE SWITCH.....	
MINIMUM SETTING ALARM PRESS. SWITCH.....	
AQUABOX PRELOADING.....	2.0
PUMP NOMINAL PRESSURE.....	4.6
REFERENCE PRESSURE(INVERTER).....	3.5
SAFETY VALVE.....	
THERMAL CUTOUT.....	
JOCKEY PUMP THERMAL CUTOUT	

RUNNING CHECKS

ROTATING DIRECTION OF EACH PUMP, NOISE, OVERHEATING.....	X
LEAKS.....	X
CONTROL PRESSURE SWITCHES.....	
NO LOAD PRESSURE SWITCH.....	
MOTOR DRIVEN PUMP CHANGE OVER SWITCH.....	X
WEEKLY/DAILY TEST CLOCK.....	
MIN./MAX. PRESSURE SWITCH SETTING ALARM.....	
WARNING AND ACOUSTIC SIGNALING (ON THE CONTROL PANEL AND REMOTE).....	
INSTRUMENTS (AMP. - VOLT.)	

SAFETY CHECKS

CONTINUITY OF THE EARTH CIRCUIT

INSULATION RESISTANCE - VOLTAGE

INSTRUMENT CODE

CH04M1

X

Note:

DATE 08.06.2017

INSPECTOR

D19B

ISTRUZIONI PER L'INSTALLAZIONE E LA MANUTENZIONE
INSTRUCTIONS DE MISE EN SERVICE ET D'ENTRETIEN
INSTRUCTIONS FOR INSTALLATION AND MAINTENANCE
INSTALLATIONSANWEISUNG UND WARTUNG
INSTRUCTIES VOOR INGEBRUIKNAME EN ONDERHOUD
INSTRUCCIONES PARA LA INSTALACION Y EL MANTENIMIENTO
РУКОВОДСТВО ПО МОНТАЖУ И ТЕХНИЧЕСКОМУ ОБСЛУЖИВАНИЮ
INSTALLATIONS - OCH UNDERHÅLLSANVISNING
INSTRUKCJA INSTALACJI I KONSERWACJI
INSTALLÁCIÓS ÉS KARBANTARTÁSI UTASÍTÁS
安装和维护说明

